



**WAH BRASS MILLS (Pvt) LTD**  
**WAH CANTT**  
**Phone +92-51-9055-21070**  
**E-mail ceo@wahbrass.com**

NO. 22-FP-CENTRIFUGAL PUMP-PUR-WBM-2020-21  
Dated. 23-01-2021

M/s .....

**AMENDMENT NO. I**

Subject: - **AMENDMENT / ELABORATION IN SPACIFICATION OF STORE**  
Ref'nce:- TE No. 22-FP-CENTRIFUGAL PUMP-PUR-WBM-2020-21, dt. 13-01-2021 for procurement of Double Suction Split Case Centrifugal Pump Assembled Including Base Frame Motor & Coupling (Opening date 19-02-2021)

Dear Sirs,

Following amendment (elaboration in Specification) is hereby made in the specification of store against under reference TE:-

Sr. No	F O R	R E A D
1	Capacity: 500 $\pm$ 25	Capacity 500 $\pm$ 25 M <sup>3</sup> / H
2	Head :- 50 $\pm$ 5	Head :- 50 $\pm$ 5 Meter
3	Motor 90 Kw, 1450 rpm	Motor- 90 KW (OR suitable according to Capacity & Head Mentioned above), 1450 rpm, 3 phase, 400 $\pm$ 10% volts, 50 Hz
4	Working Pressure	6 – 10 KP/CM <sup>2</sup>

2. All other terms and conditions of TE will remain un-changed.

Regards

xxxxsdx  
AM-SC-WBM  
FOR CEO-WBM (Pvt) Ltd.